Map ID MAP FINDINGS

Direction Distance

Distance Elevation Site EDR ID Number

Database(s) EPA ID Number

 1401
 63109 MANHOLE
 NY Spills
 \$117362242

 NNE
 EAST 4TH AND KINGS HWY
 N/A

> 1 BROOKLYN, NY

1.766 mi. 9327 ft.

Relative: SPILLS:
Higher Name: 63109 MANHOLE

Actual: Address: EAST 4TH AND KINGS HWY

23 ft. City,State,Zip: BROOKLYN, NY Spill Number/Closed Date: 1405479 / 2014-10-06

 Facility ID:
 1405479

 Facility Type:
 ER

 DER Facility ID:
 453864

 Site ID:
 498907

 DEC Region:
 2

Spill Cause: Equipment Failure

Spill Class: D4 2401 SWIS: Spill Date: 2014-08-20 Investigator: **RWAUSTIN** Not reported Referred To: Reported to Dept: 2014-08-20 Not reported CID: Water Affected: Not reported

Spill Source: Commercial/Industrial

Spill Notifier: Other
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0

Date Entered In Computer: 2014-08-20
Spill Record Last Update: 2014-10-06
Spiller Name: ERT
Spiller Company: CON ED

Spiller Address: EAST 4TH AND KINGS HWY

Spiller Company: 999 Contact Name: ERT

DEC Memo: "emis 237859 10/6/14 - Austin - 3 pints of cable oil leaked from a

capped feeder cable, onto 10 gals water in vault - Con Ed contained and cleaned up the spill - See document files for further information

- Spill closed - end"

Remarks: "cable broke inside duct into manhole, c/u pending samples"

All Materials:

Site ID: 498907 Operable Unit ID: 1248343 Operable Unit: 01 Material ID: 2249759 Material Code: 0541A Material Name: dielectric fluid Case No .: Not reported Material FA: Petroleum Quantity: .75 Units: G

Recovered: Not reported Oxygenate: Not reported